

FIRE SAFETY CERTIFICATE

Certificate No: 34/2023

Date: 14.08.2023

Current No: 241/V/2023

Certified that **THE OOTY PUBLIC SCHOOL** at S.F.NO: 992/1B3A, Onnipalayampudur, Karamadai to Airport Road, Bilichi post, Coimbatore – 641019 comprised of 1 ground floor and 2 upper floors owned /occupied by **THE OOTY PUBLIC SCHOOL** have complied with the fire prevention and fire safety requirements in accordance with the rule of the State Fire Service Rules, verified by the officers concerned of Fire Service, on **14.08.2023** in the presence of **Shri A Hallan, Manager – The Ooty Public School** and that the building space / premises is fit for occupancy up to classes XII with effect from **14.08.2023** for a period of **ONE** year in accordance with rule and subject to compliance of specific conditions as appended :-

1. The applicant will also get permission / No Objection Certificate from Other department if necessary.
2. All the Fire Extinguishers have to be recharged and maintained periodically as per code practice in IS 2171/2016

Issued ON **14.08.2023** at **PERIYANAICKENPALAYAM** by

Name & Address of Department

Name : M.KARTHIKESAN

Designation : STATION OFFICER

Signature with seal :



To

THE OOTY PUBLIC SCHOOL
S.F.No: 992/1B3A,
Onnipalayampudur,
Karamadai to Airport Road,
Bilichi Post,
Coimbatore – 641019

Shri A Hallan
14/8/23
STATION OFFICER
FIRE AND RESCUE STATION
PERIYANAICKPALAYAM,
COIMBATORE - 641 020.

ENDORSEMENT

The No Objection Certificate issued by Fire Service stand cancelled and annulled due to

.....
(reasons to be recorded)

(Name and designation of the authorised signatory)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

For THE OOTY PUBLIC SCHOOL

Shri A Hallan
Correspondent